

Attachment 12.2D – Schedule of Submissions

| Sub No | Date Rec'd | Submitter | Property Affected | Summary of Submission | Officer Comment | Officer Recommendation |
|---------------|-------------------|--|--------------------------------|--|---|---|
| 1 | 21 July 2025 | Department of Water and Environmental Regulation | Nil | No objection to development | Noted | Not applicable |
| 2 | 14 July 2025 | ACEnergy | Lot 12 Abattoir Road, Merredin | Final equipment yet to be finalised. Acoustic measures need to apply to the final equipment. | The existing Acoustics report reflects the specific equipment in the initial proposal. A revised Acoustic report will be required to be based on the final equipment selection. | That the submission be upheld and Condition No 3 be modified as follows; 3.The preparation of a revised Acoustics Consultants report to reflect the final design of the BESS facility, and that the development incorporates appropriate measures to reduce the noise impact of the facility to a level considered acceptable to the satisfaction of the local government. |